Commonwealth of Kentucky Division for Air Quality

PERMIT APPLICATION SUMMARY FORM

Completed by: Herbert R. Campbell

GENERAL INFORMATION:		
Name:	Owensboro Municipal Utilities	
Address:	4301 U. S. 60 East, Owensboro, KY 42302	
Date application received:	March 31, 2004	
SIC/Source description:	4911/electric power generation	
Source ID #:	21-059-00027	
Source A.I. #:	942	
Activity #:	APE20040001	
Permit number:	V-04-050	
APPLICATION TYPE/PERMIT ACTIVIT	<u>Y</u> :	
[] Initial issuance	[] General permit	
[] Permit modification	[]Conditional major	
Administrative	[X] Title V	
Minor	[] Synthetic minor	
Significant	[X] Operating	
[X] Permit renewal	[] Construction/operating	
COMPLIANCE SUMMARY: [] Source is out of complian [] Compliance certification APPLICABLE REQUIREMENTS LIST: [] NSR [] PSD [] Netted out of PSD/NSR	signed [] NSPS [X] SIP [] NESHAPS [] Other [] Not major modification per 401 KAR 51:017, 1(23)(b)	
MISCELLANEOUS:	or 51:052,1(14)(b)	
[X] Acid rain source		
[] Source provided terms for [] Source subject to a MAC [] Source requested case-by [] Application proposes new [X] Certified by responsible [X] Diagrams or drawings in	v-case 112(g) or (j) determination w control technology official acluded formation (CBI) submitted in application assures	
[X]Compliance Assurance N	Monitoring (CAM) Plan included in renewal application.	

EMISSIONS SUMMARY:

Pollutant	Actual (tpy) **	Potential (tpy)
PM/PM_{10}	816/221	1750/429
SO_2	5015.7	17209
NOx	10386	6908
CO	312.7	432
VOC	68.9	95

^{**} Actual based on current EIS reported values.

SOURCE PROCESS DESCRIPTION:

The source is an electric power generating plant that has two coal-fired boilers and a heating boiler. In addition, ash, coal and limestone related equipment are utilized. The coal-fired boilers have input ratings of 1507 mmBtu/hr (EU 01) and 2566 mmBtu/hr (EU 02). EU 01 is a Babcock & Wilcox cyclone furnace boiler, and EU 02 a Combustion Engineering tangentially fired steam boiler. EU 01 is equipped with overfired air (OFA), electrostatic precipitator (ESP), selective catalytic reduction (SCR) and flue gas desulfurization (FGD) and EU 02 is equipped with low NOx burners and separated overfire air (LNB/SOFA), electrostatic precipitator (ESP), selective non-catalytic reduction (SNCR) and flue gas desulfurization (FGD).

EMISSION AND OPERATING CAPS DESCRIPTION:

Natural gas burners were added as minor modification to EU 02, for additional heat input capability of 780 mmBtu/hr for loss of one pulverizer mill for the unit when a pulverizer mill was out of service in [high year] 2000. This was done to avoid future losses in capacity due to pulverizer outages and to maintain the 23533 MWh (mega watt-hours) capacity.

OPERATING LIMITATION:

Natural gas may only be fired when one coal pulverizer is out of service. The natural gas shall not run concurrently with the pulverizer, and there will be no increase in heat input rate to the Unit. The amount of natural gas combusted shall be limited to 221 MMSCF to recover the lost heat input from pulverizer mill outages.